




**ROCHESTER  
GAUGES, INC.**

**R6315-12 Transmitter Installation  
on Rochester Magnetel™ Gauge  
or Master Gauge with 3 Dial  
Mounting Brackets**

**DS-873  
Front**


ISO 9001:2008 CERTIFIED



**WARNING!** Tank may contain high pressure flammable gas. Remove two studs, one at 9 o'clock and one at 3 o'clock only, and replace with long studs. Danger of fire or explosion may exist if more than two opposing studs are removed.

**NOTE:** This detail for use with centerline Magnetel and transmitter only.

**NOTE:** This detail for use with centerline Magnetel and transmitter only.



**NOTE:** Materials and specifications are subject to change without notice. Ratings subject to change due to temperature and other environmental considerations.

**R6315-12 Transmitter Installation on Rochester Magnetel Gauge or Master Gauge with 3 Dial Mounting Brackets**




**ROCHESTER  
GAUGES, INC.**

## R6315-12 Transmitter Installation on Master Gauge with 2 Dial Mounting Brackets

**DS-873  
Back**


**R6315-12 Transmitter Installation on Master  
Gauge with 2 Dial Mounting Brackets**

**NOTE:** THIS DETAIL IS FOR USE WITH 8 INCH, OLD STYLE, MASTER GAUGE WITH DIAL MOUNTING EARS AT 12:00 & 6:00 O'CLOCK AND R6315-00012 TRANSMITTER.



**WARNING!** Tank may contain high pressure flammable gas. remove two studs, one at 9 o'clock and one at 3 o'clock only, and replace with long studs. Danger of fire or explosion may exist if more than two opposing studs are removed.

**NOTE:** THIS DETAIL IS FOR USE WITH 8 INCH MASTER GAUGE AND TRANSMITTER ONLY.



**NOTE:** IF YOUR GAUGE IS EQUIPPED WITH "OLD STYLE" 8" DIAL S/A, REPLACE WITH 8 INCH DIAL S/A P/N 5ABMS02784.

**NOTE:** Materials and specifications are subject to change without notice.  
Ratings subject to change due to temperature and other environmental considerations.

**ROCHESTER  
GAUGES, INC.**

*The Measure of Excellence*

04/12/13

11616 Harry Hines Blvd. • P.O. Box 29242 • Dallas, TX 75229 • (972) 241-2161 • FAX (972) 620-1403  
Website <http://www.rochestergauges.com> • E-mail [info@rochestergauges.com](mailto:info@rochestergauges.com)